

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8140-2027:0005 Page 1 of 1

CATEGORY: 8140 -- EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)

LISTEE: LOUISIANA-PACIFIC CORPORATION 414 Union Street, Suite 2000, Nashville, TN 37219
Contact: CW Macomber (352) 425-7457
Email: CW.Macomber@lpcorp.com

DESIGN: "LP® FlameBlock®" sheathing, 4' x 8' fire rated oriented strand board (OSB), 7/16 *Category with minimum Pyrotile thickness of 0.06, applied to fiberglass mat and Pyrotile laminate applied to one face of OSB, and "LP® SmartSide®" strand substrate lap siding cladding. Refer to the manufacturer's application instructions and product data sheets.

RATING: Compliance in accordance with Chapter 7A of the California Building Code.

INSTALLATION: In accordance with listee's printed application instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name. Model number, rating and UL label.

APPROVAL: Listed as exterior siding for use in the Wildland Urban Interface areas

*Revision 07-22-2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division