

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 8140-2027:0006 Page 1 of 1

**CATEGORY:** 8140 -- EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)

**LISTEE:** LOUISIANA-PACIFIC 414 Union Street, Suite 2000, Nashville, TN 37219  
Contact: Rex Swanson (480) 352-3667  
Email: Rex.Swanson@lpcorp.com

**DESIGN:** "LP FlameBlock™" sheathing, 4' x 8' fire rated oriented strand board (OSB), 7/16" minimum nominal thickness with minimum Pyrotile thickness of 0.06, applied direct to OSB sheathing and Pyrotile laminate applied to one face of OSB, and Cedar Sidewall Shingles, 1/2" butt end thickness cladding, or Plain Bevel solid wood siding, Cedar or other species, various widths. Refer to the manufacturer's installation instructions and product data sheets.

**RATING:** Compliance in accordance with Chapter 7A of the California Building Code.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name. Model number, rating and UL label.

**APPROVAL:** Listed as exterior siding for use in the Wildland Urban Interface areas.

05-19-11JD



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

*Listing Expires* **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
*Fire Engineering Division*