



Evaluation Listing CCMC 12353-L LP SmartSide

MasterFormat:	07 46 26
Evaluation issued:	1992-05-19
Re-evaluated:	2018-03-16
Re-evaluation due:	2019-05-19

1. Evaluation

The product conforms to CAN/CGSB-11.3-M87, “Hardboard,” as a Type 5 exterior cladding.

2. Description

The product is a Type 5 exterior hardboard siding that has a smooth or textured surface with a primer coat. The product is available in the styles and dimensions listed in Table 2.1.

Table 2.1 Styles and Dimensions of the Product

Style	Surface	Edge Type	Thickness Class (mm)
76 Series Panel⁽³⁾	smooth	square	10.5 ⁽¹⁾
76 Series Lap⁽⁴⁾	smooth	square	10.5 ⁽¹⁾
16-in. Bold Profile Double 8 in. Lap⁽⁵⁾	cedar-textured	self-aligning	12.7 ⁽²⁾

Notes to Table 2.1:

- (1) The product meets the nominal thickness class of 10.5 mm specified in CAN/CGSB-11.3-M87. This class refers to a minimum thickness of 9.5 mm and a maximum thickness of 11.2 mm.
- (2) The product meets the nominal thickness class of 12.7 mm specified in CAN/CGSB-11.3-M87. This class refers to a minimum thickness of 11.4 mm and a maximum thickness of 13.3 mm.
- (3) The product is available in a width of 1219 mm (4 ft.) with a length of 2 438 mm (8 ft.).
- (4) The product is available in a width of 305 mm (12 in.) with a length of 4 877 mm (16 ft.).
- (5) The product is available in a width of 406 mm (16 in.) with a length of 4 877 mm (16 ft.).

3. Standard and Regulatory Information

See the Annex, appended to this Listing, which summarizes the product standard.

This/These product(s) was/were evaluated to the product standard referenced in the Annex current as of 2017-10-26. Note that the Annex may have been updated since this Listing was issued to include more recent editions of the applicable product standard. Therefore, this Listing may not reflect the requirements contained in any updated version of this product standard.

Listing Holder

Louisiana-Pacific Corporation
c/o LP Building Products
414 Union Street, Suite 2000
Nashville, TN 57219
USA

Telephone: 800-450-6106

Email: marketing.center@lpcorp.com

Web site: www.lpcorp.com

Plant(s)

Roaring River, NC

Disclaimer

This Listing is issued by the Canadian Construction Materials Centre, a program of the NRC Construction Research Centre at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html, or contact the Canadian Construction Materials Centre, NRC Construction Research Centre, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone: 613-993-6189. Fax: 613-952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Date modified:

2018-03-16